



**TABLE 1  
CO2 READINGS SAMPLE SUMMARY  
MAMIE P. WHITESIDES ELEMENTARY  
CHARLESTON, SOUTH CAROLINA  
OCTOBER 20, 2023**

<b>Sample Location</b>	<b>CO2 Reading (PPM)</b>
Office	535
523	465
520	480
521	475
518	502
519	470
516	490
517	464
514	490
509	541
512	530
510	490
507	470
508	465
501A	453
36	475
Media Center	465
Computer Lab	460
331	470



332	455
329	535
330	460
319	445
318	455
317	465
316	445
314	450
315	450
313	470
312	460
310	445
311	455
309	500
308	475
301	465
110	460
111	450
113	450
112	455
114	460



115	490
117	455
116	460
125	470
128	455
127	455
129	470
130	455
132	455
131	460
133	460
335	540
333	475
334	510
Roof	410-430
Exterior - 500	450-460
Exterior - 610	420
610	450
Exterior - 517	430
Exterior 300 Hall	440
Exterior - Front Entrance	450